



Kendall – original
Eudell – 1 copy
Carol – 1 copy

CITY OF BRANSON
SEWER CONNECTION APPLICATION

PROPERTY OWNER'S NAME: _____

PROPERTY OWNER'S MAILING
ADDRESS: _____

MONTHLY WATER BILLING ADDRESS: _____

PROPERTY OWNER'S PHONE: _____ DATE: _____

CONTRACTOR/PLUMBER NAME: _____

CONTRACTOR/PLUMBER PHONE: _____

CONTRACTOR SEWER BOND ON FILE: ☐ YES ☐ NO

If answered no, contractor must put up a cash bond of \$500 before a permit will be issued.

SEWER LOCATION: _____
(LANDMARK LOCATION IF POSSIBLE)

CITY SPECIFICATIONS

- Contractor shall be licensed and bonded with the City of Branson
- Call 1-800-DIG-RITE for locates on utilities prior to excavation
- Call Public Works (417-337-8562) at least 24 hours prior for all inspections and testing:
 - Inspection (prior to backfill)
 - Air test (5psi for 15 minutes)
 - Water test (10ft of head for 15 minutes)
 - Low pressure force line (25psi for 15 minutes)
- Minimum 4" schedule 40 pvc (NO- Cellular Core allowed)
- Minimum cover: (18" to finished grade)
- Bedding: (3/4"-1" base or clean rock) (minimum 3" below pipe and 6" above pipe)
(backfill to finish grade with 0-2" rock, dirt, sand, and etc. in non-traffic areas) (any street excavation must be completely backfilled with 3/4"-1" base or clean rock)
- (NO- 90 degree ells or sweeps allowed)
- (NO- Furncos allowed)
- Cleanouts: (within 5ft of building, then every 50ft(single) or 100ft(double) (all portions of line must be reachable within 50ft of cleanout) (cleanouts must extend to finished grade with appropriate cap)
- Saddle tie-in to main: (locate tie-in on top of main. Roll tie-in into main at 45 degrees)
- Crossing of Public water mains: (18" minimal separation) (if 18" separation is not obtainable, a 4" thick x 18" wide x 10ft long concrete slab must be poured between the sewer service and Public water main, 5ft each side of where the sewer service crosses the Public water main) (bells of the sewer service must be 5ft from Public water main on each side when crossing)